



## TAMIL NADU FIRE AND RESCUE SERVICES

(Under section 13 of the Tamil Nadu Fire Service Act 1985 and  
Tamil Nadu Fire Service Rule 1990 - Appendix-III)

**PP NOC No: 3847/NOC/NMSB/2025**

Dated: 24/07/2025

District Office,  
Fire and Rescue Service,  
Chennai District.

### NO OBJECTION CERTIFICATE

Sub: Tamilnadu Fire and Rescue Services Chennai District - Issue of No Objection Certificate for Institutional Building No.343, Sholavaram Village, Madhavaram Taluk, Chennai District - Reg.

Ref: Token ID: 309100 Dated: 14/07/2025

\*\*\*\*\*

With reference to the letter cited above, **SO REDHILLS Mr.K.SEENIVASGAN** has inspected the **M/s JEEVA JYOTHI ANANDHA ILLAM** site located at No.343 Orakkadu Road ,Boodhur Village, Chennai 600 067 on 17/07/2025. This **SHELTER HOME FOR POOR CHILDREN** consisting of **Ground Floor Only** with height of **04** meters. The plot area is **4046 Sq.mts** and total buildup area is **418 Sq.mts**. The existing building occupancy is classified as **Group C – Institutional Building** as per the National Building code of India Part-IV Fire and Life Safety-2016.

No objection Certificate is issued on Fire and Rescue Services point of view to the existing building subject to fulfilment of the below conditions

**Signature valid**

Signed by: Mr.P.Loganathan DO  
Chennai Suburban,  
Northern Region, District Officer,  
Home Department  
Date:24-Jul-2025 18:58:00



## **Conditions**

The following fire safety measures should be provided in the building as listed below.

### **III. Group C - Institutional Building Conditions**

#### **7.C-2 Custodial Institutions & C-3 Panel And Mental Institutions. (Less Than 10 M In Height Upto 300 Persons)**

1. The Fire extinguishers should be provided at all floors in accordance with the IS 2190: 2010 requirements.
2. Hose reel assembly should be provided on all floors.
3. Fire service inlets fitted with NRV at ground level should be provided
4. 5000 litres capacity water tank with 450 lpm pump should be provided at the terrace.
5. If the basement is available and exceeds 200 square meters, an automatic sprinkler system should be installed in the basement. In addition with existing water tank 5000 litres capacity water tank with 450 lpm pump should be provided at the terrace.
6. Manually operated Fire Alarm call points (MCP) should be provided on all floors.
7. Staircases should have a width of 2 meters.
8. Display safety signs throughout the building.
9. Side set back area should be provided as per TNCDB rule 2019.

**To:**

**M/s JEEVA JYOTHI ANANDHA ILLAM**

No.343 Orakkadu Road ,Boodhur Village, Chennai 600 067

**Signature valid**

Signed by: Mr.P.Loganathan DO  
Chennai Suburban,  
Northern Region, District Officer,  
Home Department  
Date:24-Jul-2023 18:58:00